



aitex[®]
research & innovation center

REACTION TO FIRE

Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2024AN2671.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 24AN2671

The sample referenced as:

"RM 1069 / RM 1070/ RM 1073 / RM 1080 / RM 1081 / RM 1082"

has been tested according to the standards EN ISO 11925-2:2020 & EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

26th of November 2024



Date: 10/12/2024 14:05:42

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Rev.1

This revision cancels and replaces the previous

Joan Risueño
Head of Fire Behaviour lab.