

REACTION TO FIRE

Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2025AN1136.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 25AN1136

The sample referenced as:

"RM 1077"

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"C-s1,d0"

Date of Issue

12th of May 2025



Date: 05/06/2025 9:20:47

Digitally Signed by: DAVID MARSET GIMENO -

NIF: 21697288P

Joan Risueño
Head of Fire Behaviour lab.