

REACTION TO FIRE

Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2022AN7418.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 22AN7418

The sample referenced as:

"RM 1047"

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020 . The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

23rd of December 2022



Date: 23/12/2022 12:41:42

Digitally Signed by: DAVID MARSET GIMENO -

NIF: 21697288P

Celia Dolça
Head of Fire Behaviour lab.