

REACTION TO FIRE

Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2023AN1216.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 23AN1216

The sample referenced as:

"2. RM 1049 HIMALAYA"

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020+A1:2022. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

13th of June 2023



Date: 13/06/2023 9:19:51

Digitally Signed by: DAVID MARSET GIMENO -

NIF: 21697288P

Celia Dolça
Head of Fire Behaviour lab.