

## REACTION TO FIRE

### Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER  
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2023AN1580.



### CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 23AN1580

The sample referenced as:

**"3D Wallcovering with suedine "**

has been tested according to the standards EN ISO 11925-2:2020 and EN13823:2020. The classification according to standard EN 13501-1:2018 is:

**"D-s2,d0"**

Date of Issue

12th of July 2023



Date: 12/07/2023 18:11:05

Digitally Signed by: DAVID MARSET GIMENO -

NIF: 21697288P

Celia Dolça  
Head of Fire Behaviour lab.