

## REACTION TO FIRE

### Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER  
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2025AN1936.



### CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 25AN1936

The sample referenced as:

**"3D wallcovering on linen"**

has been tested according to the standards EN ISO 11925-2:2020. The classification according to standard EN 13501-1:2018 is:

**"E"**

Date of Issue

4th of August 2025

Date: 04/08/2025 14:56:41

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Joan Risueño  
Head of Fire Behaviour lab.