



aitex[®]
research & innovation center

REACTION TO FIRE

Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2023AN2796.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 23AN2796

The sample referenced as:

"HANJI"

has been tested according to the standards EN 12952:2020, EN 13823:2022. The classification according to standard EN 13501-1:2018 is:

"B-s1,d0"

Date of Issue

16th of January 2024

Date: 16/01/2024 9:20:49

Digitally Signed by: GEMA ESTEVE SILVESTRE -

NIF: 21666152Z

Celia Dolça
Head of Fire Behaviour lab.