

REACTION TO FIRE

Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2025AN0724.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 25AN0724

The sample referenced as:

"RM 1097"

has been tested according to the standards EN ISO 11925-2:2020 & EN 13823:2020 + A1:2022. The classification according to standard EN 13501-1:2018 is:

"D-s1,d0"

Date of Issue

26th of March 2025

Date: 26/03/2025 18:44:06

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Joan Risueño
Head of Fire Behaviour lab.