


# Reaction to fire



The applicant: **ELITIS, SAS**  
**2 BIS RUE JEAN RODIER**  
**FR-31400 TOULOUSE**

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2021AN1410



**aitex**  
textile research institute

## **CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS**

**N° 21AN1410**

The sample reference:

**“ RM 590 LIN MURAL ”**

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2018 is:

**“B-s2,d0”**

Alcoy, July 02nd 2021.

**Celia Dolça**

HEAD OF FIRE BEHAVIOUR LAB.