

TYPE TEST

The applicant: **ELITIS, S.A.**
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

Attending the described tasks for the verification of conformity system 3 and the detailed features at harmonised product standard UNE-EN 15102:2008+A1:2012 V2



Notified Body No. 0161

Nº 14AN0322

Declares at classification report no. 2014AN0322 that the decorative wall covering referenced as:


"ECLAT RM 887"

have been tested following the mentioned harmonised product standard requirements, being classified according to UNE-EN 13501-1 as:

"B-s1,d0"

Valid for the conformity declaration required at clause ZA.2.2 or the harmonised product standard.

Alcoy, February 10th 2014.



Raquel Muñoz González
CHIEF OF INNOVATION AREA



Jordi Ferri Pascual
HEAD OF FIRE DEPARTMENT

