


Reaction to fire



The applicant:

ELITIS, SAS
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

is authorized to place the label "Classification of Reaction to Fire of Construction Products " according to the report N° 2019AN2808



aitex
textile research institute

CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

N° 19AN2808

The sample reference:

“RAW RAFFIA RM 975”

has been tested according to the standards EN ISO 11925-2:2010 and EN 13823:2010+A1:2014. The classification according to standard EN 13501-1:2018 is:

“C-s1,d0”

Alcoy, October 18th 2019.

Celia Dolça
HEAD OF FIRE BEHAVIOUR LAB.