

TYPE TEST



The applicant: **ELITIS, S.A.**
2 BIS RUE JEAN RODIER
31400 TOULOUSE-FRANCIA

Attending the described tasks for the verification of conformity system 3 and the detailed features at harmonised product standard UNE-EN 15102:2008+A1:2012 V2



aitex
textile research institute

Notified Body No. 0161

Nº 14AN0208

Declares at classification report no. 2014AN0208 that the decorative wall covering referenced as:


"ROBINSON RM 904"

have been tested following the mentioned harmonised product standard requirements, being classified according to UNE-EN 13501-1 as:



"B-s1,d0"

Valid for the conformity declaration required at clause ZA.2.2 or the harmonised product standard.

Alcoy, January 29th 2014.



Raquel Muñoz González
CHIEF OF INNOVATION AREA



Jordi Ferri Pascual
HEAD OF FIRE DEPARTMENT