



aitex[®]
research & innovation center

REACTION TO FIRE

Applicant:

ELITIS, SAS

2 BIS RUE JEAN RODIER
FR-31400 TOULOUSE

Is authorized to place the label "Classification of Reaction to Fire of Construction Products" according to the 2024AN0581.



CLASSIFICATION OF REACTION TO FIRE OF: CONSTRUCTION PRODUCTS

Nº: 24AN0581

The sample referenced as:

"Cordes sensibles x Véronique de Soultrait"

has been tested according to the standards EN ISO 11925-2:2020 and EN 13823:2020. The classification according to standard EN 13501-1:2018 is:

"B-s3,d0"

Date of Issue

12th of April 2024



Date: 12/04/2024 10:12:36

Digitally Signed by: JOAN RISUEÑO CABANES -

NIF: 48605765A

Joan Risueño
Head of Fire Behaviour lab.