



Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference

-

our reference

JW/1091

Gent

2025-02-10

Certification report 19/1091

1. Description of the wall covering:

Product family	Type 5: Decorative wall covering consisting of: Non-woven + 10 mm mousse
Total mass	700 -856 g/m ²

2. Test executed:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

D - s1, d0

field of application: glued on end-use substrates having a density of 1350 kg/m³ or higher and classified

A2-s1,d0 or A1

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

addressee	our reference	Gent	page
Arte nv	JW/1091	2025-02-10	2
Related commercial names to this product group	ENIGMA: Flex, Select INTRIGUE: Rosace OBJET SPECTRA: Carrelage TERRA: Arcila		
The obtained classification is based on the next test reports	2020AN2199 2020AN2205		
Validity of the certificate	2026-01-19		

Jo Wynendaele, PhD
Consultant Floor and Wall Coverings

